

Office of the State Fire Marshal (OSFM) – Example Inspection Checklist

References:

NFPA 101 – Life Safety Code

NFPA 58 – Liquefied Petroleum Gas Code

NFPA 96 – Standard for Ventilation Control and Fire Protection of Commercial Cooking Operations

Part 150 – Title 41 IL Admin Code Part 150 Race Track Rules for Fire Safety

Part 160 – Title 41 IL Admin Code Part 160 Storage, Transportation, Sale and Use of Gasoline and Volatile Oils (Storage)

Part 180 – Title 41 IL Admin Code Part 180 Storage, Transportation, Sale and Use of Gasoline and Volatile Oils (Dispensing)

Part 200 – Title 41 IL Admin Code Part 200 Storage, Transportation, Sale, and Use of Liquefied Petroleum Gas

PA 103-0272 – Smoke Free Illinois Act

IDPH – Illinois Department of Public Health

1. **Extinguisher required / not present 2A:10BC “K”**
NFPA 101 / 2015 ed. / 11.11.5
Part 150.70 f)
Office of the State Fire Marshal (OSFM) – Requirement for Vendors – pages 1 & 2
2. **Extinguisher not tagged / not current 2A:10BC “K”**
NFPA 10 / 2007 ed.
Part 150.80 d) 10)
Office of the State Fire Marshal (OSFM) – Requirement for Vendors – page 1
3. **Non-approved cooking equipment being used**
NFPA 101 / 2015 ed. / 12.7.5.3.9
NFPA 96 / 2008 ed.
Part 150.60 a) 1), 150.60 a) 5)
Office of the State Fire Marshal (OSFM) – Requirement for Vendors – page 2
4. **Cooking shielding / separation distance not met**
NFPA 96 / 2008 ed.
IDPH – Food Safety Fact Sheet for Vendors page 1 & 2
Office of the State Fire Marshal (OSFM) – Requirement for Vendors – page 2
5. **Suppression system not tagged / not current**
NFPA 96 / 2008 ed.
Office of the State Fire Marshal (OSFM) – Requirement for Vendors – page 2
6. **Smoking in unauthorized area / no smoking signs not present**
NFPA 101 / 2015 ed. / 11.11.4.2.2, 12.7.8, 13.7.8
Part 150.80 f) 2) A)
PA 103-0272
Office of the State Fire Marshal (OSFM) – Requirement for Vendors – page 1
7. **Number of LPG tanks allowed exceeded (Maximum of 6)**
NFPA 58 / 2011 ed.
Office of the State Fire Marshal (OSFM) – Requirement for Vendors – page 4
8. **LPG tanks not secured properly / upright**
NFPA 101 / 2015 ed. / 11.11.6.1.4
NFPA 58 / 2011 ed.
Office of the State Fire Marshal (OSFM) – Requirement for Vendors – page 4
9. **LPG Tank inside building or vendor space**
NFPA 101 / 2015 ed. / 11.11.6.1.3
NFPA 58 / 2011 ed.
Part 200 rules
Part 150.60 a) 2)
Office of the State Fire Marshal (OSFM) – Requirement for Vendors – page 4
10. **Flammable / Combustible liquid use / storage**
Part 150.60 c)
Part 160 rules, Part 180 rules
Office of the State Fire Marshal (OSFM) – Requirement for Vendors – pages 4 & 5
11. **Ungrounded / lightweight extension cord(s) being used**
NFPA 70 / 2014 ed.

- Part 150.80 f) 2) B)
Office of the State Fire Marshal (OSFM) – Requirement for Vendors – pages 1 & 2
- 12. Misc. Electrical Violations**
NFPA 70 / 2014 ed.
Office of the State Fire Marshal (OSFM) – Requirement for Vendors – pages 2 & 3
- 13. Exits obstructed / blocked**
NFPA 101 / 2015 ed. / 4.5.3.2, 7.1.10.2.1
Office of the State Fire Marshal (OSFM) – Requirement for Vendors – page 1
- 14. Tent material not rated / no proof of rating**
NFPA 101 / 2015 ed. / 11.11.2.1
Office of the State Fire Marshal (OSFM) – Requirement for Vendors – page 3
- 15. Non-approved trash containers in use**
NFPA 101 / 2015 ed. / 10.3.9.1
Part 150.80 c) 2)
Office of the State Fire Marshal (OSFM) – Requirement for Vendors – page 1
- 16. Fire lane obstructed / blocked**
Part 150.80 f) 2) H)
Office of the State Fire Marshal (OSFM) – Requirement for Vendors – page 1
- 17. Hydrant obstructed / blocked**
Part 150.70 b) 3), Part 150.80 f) 2) K)
Office of the State Fire Marshal (OSFM) – Requirement for Vendors – page 1
- 18. Sleeping, cooking in unauthorized areas / barn aisles blocked**
Part 150.60 a) 5), Part 150.80 f) 2) E)
Office of the State Fire Marshal (OSFM) – Requirement for Vendors – page 1