

Office of the State Fire Marshal (OSFM) Example Inspection Checklist

- 1 Extinguisher Required Not Present 2A:10BC “K”**
NFPA 101/2015 / 11.11.5
Part 150.70 f
Office of the State Fire Marshal (OSFM) – Requirements for Vendors 2025 - page 1 & 2
- 2 Extinguisher Not Tagged / Not Current A:10BC “K”**
NFPA 10/2007
Part 150.80 d 10
Office of the State Fire Marshal (OSFM) – Requirements for Vendors 2025 - page 1 & 2
- 3 Non-Approved Cooking Equipment being used**
NFPA 96 / 2008
NFPA 101/2015 / 12.7.5.3.9
Part 150.60 a 1 / 150.60 a 5
Office of the State Fire Marshal (OSFM) – Requirements for Vendors 2025 - page 2
- 4 Cooking Shielding/Separation Distance not met**
NFPA 96 / 2008
Office of the State Fire Marshal (OSFM) – Requirements for Vendors 2025 - page 2
- 5 Suppression System Not Tagged / Not Current**
NFPA 96 / 2008
Office of the State Fire Marshal (OSFM) – Requirements for Vendors 2025 - page 2
- 6 Smoking in unauthorized area, No Smoking Signs not present**
NFPA 101/2015 / 11.11.4.2.2, 12.7.8.2, 13.7.8.2
Part 150.80 f 2 A / Part 270.665 / PA103-0272
Office of the State Fire Marshal (OSFM) – Requirements for Vendors 2025 - page 1 & 3
- 7 # LPG tanks allowed are exceeded (Maximum of 6)**
NFPA 58/2011 / 6.4.2
Office of the State Fire Marshal (OSFM) – Requirements for Vendors 2025 - page 4
- 8 LPG Tanks Not Secured Properly / Upright**
NFPA 101/2015 / 11.11.6.1.4
Part 200 / NFPA 58 (2011)
Office of the State Fire Marshal (OSFM) – Requirements for Vendors 2025 - page 4
- 9 LPG Tank inside building or vendor space**
NFPA 101/2015 / 11.11.6.1.3
Part 200 / NFPA 58 (2011)
Part 150.60 a 2
Office of the State Fire Marshal (OSFM) – Requirements for Vendors 2025 - page 2 & 4
- 10 Flammable / Combustible Liquid Use / Storage**
NFPA 101/2015 / 12.7.5.5.1
Part 150.60 c
Part 160 & Part 180 Rules
Office of the State Fire Marshal (OSFM) – Requirements for Vendors 2025 - page 1, 4 & 5

- 11 Ungrounded / Lightweight extension cord(s) being used**
NFPA 70 (2014)
Part 150.80 f 2 B
Office of the State Fire Marshal (OSFM) – Requirements for Vendors 2025 - page 1, 2 & 3
- 12 Misc. Electrical Violations**
NFPA 70 (2014)
Office of the State Fire Marshal (OSFM) – Requirements for Vendors 2025 - page 1, 2 & 3
- 13 Exits Obstructed / Blocked**
NFPA 101,/2015 / 4.5.3.2, 7.1.10.2.1
Office of the State Fire Marshal (OSFM) – Requirements for Vendors 2025 - page 1
- 14 Tent Material Not Rated / No Proof of Rating**
NFPA 101/2015 / 11.11.2.1
Office of the State Fire Marshal (OSFM) – Requirements for Vendors 2025 - page 3 & 4
- 15 Non - Approved Trash Containers in use**
NFPA 101/2015 / 10.3.9.1
Part 150.80 c 2
Office of the State Fire Marshal (OSFM) – Requirements for Vendors 2025 - page 1 & 4
- 16 Fire Lane Obstructed / Blocked**
Part 270.335 / Part 270.345
Part 150.80 f 2 H
Office of the State Fire Marshal (OSFM) – Requirements for Vendors 2025 - page 1
- 17 Hydrant Obstructed / Blocked**
Part 150.70 b 3 / Part 150.80 f 2 K
Office of the State Fire Marshal (OSFM) – Requirements for Vendors 2025 - page 1
- 18 Sleeping, cooking in unauthorized areas, Barn aisles blocked**
Part 270.360 / Part 270.665
Part 150.8 f 2 / 150.60 a 1 /
Office of the State Fire Marshal (OSFM) – Requirements for Vendors 2025 - page 1